



Received: 05/01/2014 Completed: 05/02/2014 Letter: R JB P.O.#: Test Report #: 3-01939-0-

Client's Identification Style: Duratex 7 oz Matte Scrim Banner. Width: 38". Finish: Matte. Weight: 7 oz. End Use: Display Media.

Tested For: **Rob Pinedo** Key Test: NFPA 701-2010 TM#2 Flat 425
 Pitman Co./Agfa
 21908 E. Valley Blvd Tel: 1-(800)-274-1451 Ext: 2896
 City of Industry, CA 91789 Fax: 1-(909)-595-1451

PC:1H

TEST PERFORMED: NFPA 701 - Standard Methods of Fire Tests for Flame Propagation of Textiles and Films - 2010 Edition - Test Method #2 - Flat Sheet Specimens

SPECIMEN CONFIGURATION: Single Layer; Multi Layer

RESULTS REPORTED: Initially After 72 hours water leaching
 After 3 dry cleanings After 100 hours accelerated weathering
 After 5 launderings @ 160°F

RESULTS:

Length Specimen #	Afterflame (seconds)	Drip Burn (seconds)	Char Length (mm)
1	0	0	310
2	0	0	339
3	0	0	340
4	0	0	350
5	0	0	305
6	0	0	349
7	0	0	290
8	0	0	320
9	0	0	375
10	0	0	287

APPROXIMATE WEIGHT OF MATERIAL (as measured by Govmark): 264 g/m²

FAILURE CRITERIA: For each individual specimen --

Afterflame	Drip Burn	Char Length
Exceeds 2.0 seconds	Exceeds 2.0 seconds	Exceeds 435 mm (17.1")

RETEST PROVISION: Test 5 additional specimens if only 1 specimen fails.

CONCLUSION: Based on the above Results and Failure Criteria, the item tested:

Passes; Fails; Requires testing of 5 additional specimens

Received: 05/01/2014	Completed: 05/02/2014	Letter: R	JB	P.O.#:	Test Report #:	3-01939-0-
Client's Identification	Style: Duratex 7 oz Matte Scrim Banner. Width: 38". Finish: Matte. Weight: 7 oz. End Use: Display Media.					
Tested For: Rob Pinedo	Key Test: NFPA 701-2010 TM#2 Flat					425
Pitman Co./Agfa 21908 E. Valley Blvd City of Industry, CA 91789			Tel: 1-(800)-274-1451		Ext: 2896	
			Fax: 1-(909)-595-1451			

PRECONDITIONING: 1 hr @ 220°F (Standard)
 24 hrs @ 68±9°F (Alternate: Material shrinks/distorts @ 220°F)

REMARKS: None.

CONVERSION FACTORS:

mm ÷ 25.4 = inches
 g/m² ÷ 28.35 x .835 = oz/yd²

CERTIFICATION: I certify that the above results were obtained after testing specimens in accordance with the procedures and equipment specified by NFPA 701 - 2010 Edition Test Method #2 Flat Sheet Specimens.



MAY 08 2014

AUTHORIZED SIGNATURE
 THE GOVMARK ORGANIZATION, INC. /pm

/gb

MS. PHYLLIS PETTIT

(Page 2 of 2)